


From: william.bumpers@bakerbotts.com [mailto:william.bumpers@bakerbotts.com]
Sent: Tuesday, October 16, 2012 08:27 AM
To: Brooks.Phillip@epamail.epa.gov <Brooks.Phillip@epamail.epa.gov>; Dunn, Jason (ENRD)
Cc: Gordon.Polozola@nrgenergy.com <Gordon.Polozola@nrgenergy.com>
Subject: Re: Revised CDE

For PM, MATS requires PM CEMS and an emission rate of 0.03. The CD has the same requirements. Also, the certification of the CEMS are explicit in the MATS rule. The CD provisions, based on Part 60, really do not do anything except impose additional recordkeeping burdens. (b) (4)

The text "(b) (4)" is followed by two lines of redacted content, represented by solid black bars. The first bar is long and spans most of the width of the text area. The second bar is shorter and positioned below the first one.